



**Environmental and Laboratory Services**

Dover Location:  
90 1/2 West Blackwell St., Dover, NJ 07801  
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:  
8A Railroad Ave, Marlboro, NJ 07746  
Phone: (732) 308-3500, Fax (732) 308-3503

Date: May 24, 2024  
Client: Stepping Stones School  
Address: 6 Kingsbridge Rd, Bldg. 6, Suite B  
Fairfield, NJ 07004

PWSID#:  
Project Location:

## Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	240514004-001							
Sample Location:	SSS-POE-STF-KC-DW1	Customer Sample Number:								
Sampled By:	D. Diaz									
Sample Date/Time:	5/15/2024 7:06									

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/20/2024	12:21	BPD	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	240514004-002							
Sample Location:	SSS-POE-STF-KC-DW1	Customer Sample Number:								
Sampled By:	D. Diaz									
Sample Date/Time:	5/15/2024 7:07									

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	< 2.00	µg/L	5	5/20/2024	12:45	BPD	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 240514004-003							
Sample Location: SSS-NS-DW2		Customer Sample Number:							
Sampled By: D. Diaz									
Sample Date/Time: 5/15/2024 7:09									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/20/2024	12:50	BPD	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 240514004-004							
Sample Location: SSS-NS-DW2		Customer Sample Number:							
Sampled By: D. Diaz									
Sample Date/Time: 5/15/2024 7:10									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	< 2.00	µg/L	5	5/20/2024	12:56	BPD	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 240514004-005							
Sample Location: SSS-STU-KC-DW3		Customer Sample Number:							
Sampled By: D. Diaz									
Sample Date/Time: 5/15/2024 7:11									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	5/20/2024	13:02	BPD	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 240514004-006							
Sample Location: SSS-STU-KC-DW3		Customer Sample Number:							
Sampled By: D. Diaz									
Sample Date/Time: 5/15/2024 7:12									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor

Sample Matrix:	Drinking Water	Lab Sample Number:	240514004-006
Sample Location:	SSS-STU-KC-DW3	Customer Sample Number:	
Sampled By:	D. Diaz		
Sample Date/Time:	5/15/2024 7:12		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	< 2.00	µg/L	5	5/20/2024	13:08	BPD	2	1


Sample Matrix:	Drinking Water	Lab Sample Number:	240514004-007
Sample Location:	Field Blank	Customer Sample Number:	
Sampled By:	D. Diaz		
Sample Date/Time:	5/15/2024 7:01		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead	SM3113B	< 2.00	µg/L	5	5/20/2024	13:14	BPD	2	1

NJ Lab ID# 14013 (Dover)  
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.  
 Any method followed by an asterisk (\*) was analyzed by the Agra-Marlboro laboratory.  
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

  
 Michael J Furrey, President

May 24, 2024



# CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

24051400  
240514004

Customer Name:	Stepping Stones School	Report to:	The Arc of Essex County	Agra Environmental Services	# Asc./HCl Vials	pH: _____
Location:			Frank Cinque	90 1/2 West Blackwell Street	# HCl Vials	pH: _____
Address:	6 Kingsbridge Rd, Bldg. 6, Suite B		fcinque@arcessex.org, ,	Dover, NJ 07801	# Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	Cl <sub>2</sub> : _____
	Fairfield, NJ, 07004			Phone: (973) 989-0010	# 7 HNO <sub>3</sub> , 250	pH: 4.2
Customer Contact:	Susan Lenczyk		slenczyk@arcessex.org	Fax: (973) 989-0156	# H <sub>2</sub> SO <sub>4</sub>	pH: _____
Phone: Work/Cell	973-535-1181 / 973-535-1181 x1248				# NaOH	pH: _____
					# unpreserved	_____
					# other	_____
					# other	_____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 1

Project: Pb	Collection	PWSID#	for laboratory use only						Field Analysis		
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl <sub>2</sub> or PO <sub>4</sub>
240514004-001	SSS-POE-STF-KC-DW1	5/15/24	0706	X		DW	1	HNO3	Lead-1st Draw		
240514004-002	SSS-POE-STF-KC-DW1 - Flush		0707	X		DW	1	HNO3	Lead		
240514004-003	SSS-NS-DW2		0709	X		DW	1	HNO3	Lead-1st Draw		
240514004-004	SSS-NS-DW2 - Flush		0710	X		DW	1	HNO3	Lead		
240514004-005	SSS-STU-KC-DW3		0711	X		DW	1	HNO3	Lead-1st Draw		
240514004-006	SSS-STU-KC-DW3 - Flush		0712	X		DW	1	HNO3	Lead		
240514004-007	Field Blank		0701	X		DW	1	HNO3	Field Blank		

Sampled By (name/company): D. Diaz / Agra

Are these samples for compliance? (circle one): Yes  or No

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard  NJ Reduced  Other (Specify)

Cooler Temperature Upon Receipt at lab: 11.4°C

**Sample Custody Exchanges (Please use full legal signature)**

Relinquished By: <u>Daniel Diaz</u>	Date: <u>5/15/24</u>	Time: <u>1322</u>	Received By: <u>[Signature]</u>	Date: <u>5/15/24</u>	Time: <u>1340</u>	Comments: @7am, 3x 1st draw, 3x 30 sec flush. 250mL bottles
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	
Relinquished By:	Date:	Time:	Received By:	Date:	Time:	

Date Faxed \_\_\_\_\_  
Invoice Number \_\_\_\_\_

Is sample known to be hazardous? (circle one)  
Yes or No